



सहायक आयुक्त का कार्यालय

मण्डलपालडी, सीमा शुल्क, अहमदाबाद-

चौथी मंजिल 380009-हुडको बिल्डिंग, ईश्वर भुवन के पास, नवरंगपुरा, अहमदाबाद ,.

दूरभाष 26579963 (079) : फैक्स 26587590 (079) : ईमेल-: customs-paldi@gov.in

F.No. I/(22)/BILL/32/2026-DIV-AHMD-CUS

Date: 17-03-2026

TENDER NOTICE NO. 01/2026

Sealed quotations are invited from authorized dealers, suppliers or manufacturers for supply, installation and commissioning of SITC of Online UPS with 2 Hours Backup installation with existing electrical wiring setup as per following configuration:

Sl. No.	UPS WITH BACKUP AND INSTALLATION	Minimum Configuration/Specification required	Quantity Required	Site for installation
1.	SITC of Online UPS with 2 Hours Backup installation with existing electrical wiring setup	Rating (in KVA) 5 Input Voltage (AC, 50 Hz) Single Phase, 160V - 260V Output Voltage (AC, 50 Hz) Single Phase, 230V±1%, Availability of Inbuilt Isolation Transformer, Type of Battery SMF-VRLA (Sealed Maintenance Free-Valve Regulated Lead Acid) / Stationary Lead Acid Batteries	01 (ONE)	For Foreign Post Office, Meghaninagar, Ahmedabad

2. The quotation may be submitted in sealed cover.

3. The financial bid should contain only the financial charges.

4. The firms should submit the quotations in sealed envelopes and it should be placed in the main sealed envelope super scribed "Tender Quotations for SITC of Online UPS with 2 Hours Backup installation with existing electrical wiring setup for Customs Division Paldi, Customs Ahmedabad" and the same should be addressed to "The Assistant Commissioner of Customs Division Paldi, Customs, Ahmedabad, at 4th Floor, HUDCO Building, Nr. Iswarbhuvan, Navrangpura, Ahmedabad – 80009", and should reach the office latest by 04.00 PM on 26.03.2026 and no quotations will be entertained after 26.03.2026.

TENDER PROCESS:

- a. Quotations may be submitted in sealed envelopes on or before bid submission closing date & time.
- b. Not more than one tender shall be submitted by a bidder having business relationship. Under no circumstances shall father and his son (s) or other close relations who have business relationship with one another (i.e. when one or more partner(s)/director(s) are common) be allowed to tender for the same contract as separate competitors. A breach of this condition shall render the tenders of both parties liable to rejection.
- c. Bidder, who has downloaded the tender from the website, shall not Tamper /modify the tender from including downloaded price bid template in any manner. In case same is found to be tampered/modified in any manner, tender will be completely rejected and tender is liable to be banned.
- d. Work order will be given to the bidder who quotes the lowest price.
- e. Late submission of tenders shall not be accepted in any case.
- f. The bidder shall abide by the Terms & Conditions as specified in this Notice.
The Assistant Commissioner of Customs Division Paldi, Customs,
- g. Ahmedabad reserves the right to accept or reject any or all the tenders without assigning any reason whatsoever.

For any query or any information, the same may be obtained from Superintendent (Admin.), 4th Floor, HUDCO Building, Nr. Ishwar Bhuvan, Navrangpura, Ahmedabad – 380009.

(Ashok Haribhai Dodia)
Assistant Commissioner
Customs Division-Paldi
Ahmedabad

Copy to:

1. Notice Board.
2. The Superintendent, System Cell, Customs, H.Q., Ahmedabad for displaying on website.

Pre-Qualification

OEM Criteria

- OEM must be registered in India since last 5 years. Document of registration must be upload.
- OEM average annual turnover minimum 1Crore in last three financial years.
- Proposed System must be BIS supported and proposed model must be present in BIS certificate attached along with other bid documents.
- Test report of Proposed product must be submitted along with bid documents.
- OEM warranty for Cameras and NVR must be covers 2 Years.
- OEM must be certified with following

1. **ISO: 9001 : 2015**
2. **ISO: 14001 : 2015**
3. **ISO: 45001 : 2018**
4. **Test Format as per IS 16242(Part 1): 2014/IEC 62040-1: 2008**
5. **BIS Certificate**

Bidder Criteria

- Bidder must be registered and from Gujarat since last 3years. Document of registration must be upload.
- Bidder must not be black listed by any government agency in past. Same is to be undertake by bidder on Rs. 300 stamp papers.
- Bidder must be authorized partner or system integrator from OEM. Manufacturer Authorization Form to Bid specific must be submit.
- Bidder firm must be certified ISO 9001 and registered before the bid publish date.
- Bidder need to submit data sheet of products proposed in bid with sign and stamp on it.
- Bidder must be submitting compliance document on letterhead with sign and stamp.
- Bidder must have experience of UPS and Networking and Electronic installation in single government order in last 1 year.
- Bidder has to provide backup facility in UPS for minimum 2 Hours.
- For backup facility Bidder has to provide batteries along with its stand and installation.
- Bidder has to Complete the project by giving all the connection to the existing system.
- Payment will be released only after inspection done by buyer side and get fully satisfied.

ANNEXURE-A**Tender Notice No. 01/2026****DECLARATION REGARDING ACCEPTANCE OF TERMS AND
CONDITIONS CONTAINED IN THE TENDER DOCUMENT**

To
The Assistant Commissioner,
Customs Division-Paldi,
Customs, Ahmedabad
4th Floor, HUDCO Bhavan,
Navrangpura,
Ahmedabad-380 009.

Sir,

I have carefully gone through the Terms and Conditions contained in the Tender Notice No. 01/2026 dated 17.03.2026 regarding purchase of SITC of Online UPS with 2 Hours Backup installation with existing electrical wiring setup for Office of the Assistant Commissioner of FPO, Customs, Ahmedabad.

I declare that all the **Terms and Conditions** of this Tender Notice are acceptable to my Company/Firm/Agency. My Company/ Firm/Agency does not have any terms and conditions of its own in respect of quotation being submitted for the same. I further certify that I am an authorized signatory of my company/ Firm/Agency and am, therefore, competent to make this declaration.

Yours very truly,

Signature of authorized signatory with date:

Name:

Designation:

Name of firm:

Address:

ANNEXURE-B**Tender Notice No. 01/2026****(Technical Bid to be placed in separate sealed cover)**

1. Description of offered SITC of Online UPS with 2 Hours Backup installation with existing electrical wiring setup

(a) Brand Name- _____

(b) Model No. - _____

Configuration Compliance Sheet		Compliance (Yes/No)
Rating (in KVA)	5	
Input Voltage (AC, 50 Hz)	Single Phase, 160V - 260V	
Output Voltage (AC, 50 Hz)	Single Phase, 230V±1%,	
Availability of Inbuilt Isolation Transformer	Yes	
Type of Battery	SMF-VRLA (Sealed Maintenance Free-Valve Regulated Lead Acid) / Stationary Lead Acid Batteries	
Performance Parameters		
Description of Stores	Online UPS with IGBT-PWM ((Insulated Gate Bipolar Transistor - Pulse Width Modulation) switching technology and maximum 2% Total Harmonic Distortion at Linear Load	
Input Voltage (AC, 50 Hz)	Single Phase, 160V - 260V	
Output Voltage (AC, 50 Hz)	Single Phase, 230V±1%,	
Availability of Inbuilt Isolation Transformer	Yes	

Overall Efficiency (in %)	80% - 90	
Minimum Overload Capacity of Online UPS	150% of Rating in KVA for 60 seconds	
Standard Accessories	Input and Output Power Cables, Battery Connecting Cables and Lugs, Battery Rack, Communication Cable, Battery Fuse	
Type of Battery	SMF-VRLA (Sealed Maintenance Free-Valve Regulated Lead Acid) / Stationary Lead Acid Batteries	
Backup Time	120 minute	
Standard Protection For Online UPS with Battery	Under Voltage Protection , Over Voltage Protection, Short Circuit Protection, Over Load Protection, Over Temperature Protection	
Online UPS Metering Information	Input and Output Voltage, Output Power, Battery Voltage	
Online UPS Alarms and Indicators	UPS Status, Battery Charging and Discharging, Overload Voltage, Audible Alarm for Low Battery/Battery Voltage	
Type of Mounting of Online UPS	Floor Standing	
Ingress Protection	IP21	
Operating Temperature Range (Lower Limit)	- 5°C to 0°C	
Operating Temperature Range (Upper Limit)	35°C to 40°C	
Warranty	2 year	

ANNEXURE-C**Tender Notice No. 01/2026****(Financial Bid to be placed in separate sealed cover)**

1. Description of offered SITC of Online UPS with 2 Hours Backup installation with existing electrical wiring setup:-

(a) Brand Name- _____

(b) Model No.- _____

Price (Inclusive of all taxes and installation charges) SITC of Online UPS with 2 Hours Backup installation with existing electrical wiring setup	In digits Rs. _____ /-*
	In words- (Rupees _____)

*No extra payment will be made in any circumstances over and above the rate quoted here. Hence, it is advised to inspect the place of installation before quoting the rate.

Signature of authorized signatory with date:

Name:
Designation:
Name of firm:
Address: